



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY
VIDYANAGAR, KASARAGOD - 671123

Tele phone No : 04994 255791, E-mail - qclabkasaragod@gmail.com

Test Report



TC-16085

Test Report No:KWA/QA/R/12/97/J/92/032

ULR No.: TC-16085250000001415F

Report Date 20-12-2025

Customer Name and Address SRI VIVEKANANDHA CENTRAL SCHOOL PERLA SRI VIVEKANANDHA CENTRAL SCHOOL PERLA P O PERLA KASARAGOD-671552 7012982749 HI FHC-PERLA	1. Date of receipt	18-12-2025
	2. Sampling done by	The Customer(QUA_287166)
	3. Sample Code	66/25/44
	4. Source of sample	BORE WELL
	5. Sample condition	GOOD
	6. Name of sample	Drinking water
	7. Purpose of test	NON DOMESTIC
	8. Sample quantity	2 litre
	9. Test performing dates	From:18/12/2025 To: 19/12/2025

	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012 Amendment No. 4 Nov 2021	Result
1	Colour	HU	IS 3025 (Part 4) : 2021	5	—
2	Odour	--	IS 3025 (Part 5) : 2018	Agreeable	—
3	Taste	--	IS 3025 (Part 8) : 2023	Agreeable	—
4	Turbidity	NTU	IS 3025 (Part 10) : 2023	1	1
5	pH at 25°C	--	IS Part 11 : 2022	6.5 to 8.5	7.8
6	Total Alkalinity (as CaCO ₃)	mg/L	IS 3025 (Part 23) : 2023	200	—
7	Total Dissolved Solids (TDS 180°C	mg/L	IS 3025 (Part 16) : 2023	500	—
8	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (Part 21) : 2023	200	66.5
9	Calcium (as Ca)	mg/L	IS 3025 (Part 40) : 2024	75	—
10	Magnesium (as Mg)	mg/L	IS 3025 (Part 46) : 2023	30	—
11	Chloride (as Cl)	mg/L	IS 3025 (Part 32) : 2019	250	11.64

Note :

1. The results stated above related only to the sample(s) submitted for testing.
2. This test certificate shall not be reproduced except in full without the written approval of the laboratory.
3. Sample will be retained in the laboratory for 5 days.

Haritha A
Reviewed & Authorised By
Haritha A
Quality Manager
Quality Control District Lab
Kerala Water Authority
Vidyanagar, Kasaragod - 671123

* End of Report *

KWA/QC/DL/KSD/R/17	Issue No: 02	Issue Date: 06.05.2022	Rev No: 005	Rev Date: 17.05.2025
--------------------	--------------	------------------------	-------------	-------------------------