



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY
VIDYANAGAR, KASARAGOD - 671123

Tele phone No : 04994 255791, E-mail - qclabkasaragod@gmail.com

Test Report

Test Report No:KWA/QA/R/12/97/J/92/032

Report Date 20-12-2025

Customer Name and Address SRI VIVEKANANDHA CENTRAL SCHOOL PERLA SRI VIVEKANANDHA CENTRAL SCHOOL PERLA P O PERLA KASARAGOD-671552 7012982749 HI FHC-PERLA	1. Date of receipt	18-12-2025
	2. Sampling done by	The Customer(QUA_287166)
	3. Sample Code	66/25/44
	4. Source of sample	BORE WELL
	5. Sample condition	GOOD
	6. Name of sample	Drinking water
	7. Purpose of test	NON DOMESTIC
	8. Sample quantity	2 litre
	9. Test performing dates	From: 18-12-2025 To: 19-12-2025

Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012 Amendment No. 4 Nov 2021	Result
1	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (Part 14) : 2013 (Reaffirmed 2023)		176.3
2	Acidity	(mg/litre)	IS 3025 (Part 22) : 2024		--
3	Sulphate (as So ₄)	(mg/litre)	IS 3025 (Part 24/Sec 1) : 2022	200	--
4	Fluoride (as F)	(mg/litre)	APHA 24 th Edition 4500- F-D SPADNS Method	1	--
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) : 2004	1	0.3
6	Nitrate (as NO ₃)	(mg/litre)	APHA 24th Edition 4500 NO ₃ - B (UV Screening method)	45	<1.0
7	Residual Chlorine	(mg/litre)	IS 3025 (Part 26) : 2021	0.2	--

Note :

1. The results stated above related only to the sample(s) submitted for testing.
2. This test certificate shall not be reproduced except in full without the written approval of the laboratory.
3. Sample will be retained in the laboratory for 5 days.

Reviewed & Authorised By
Haritha A
Haritha A
Quality Manager
Quality Control District Lab
Kerala Water Authority
Vidyanagar, Kasaragod - 671123

* End of Report *

KWA/QC/DL/KSD/R/17	Issue No: 03	Issue Date: 25.02.2023	Rev No: 005	Rev Date: 05.04.2025
--------------------	--------------	------------------------	-------------	-------------------------