



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY
VIDYANAGAR, KASARAGOD - 671123

Tele phone No : 04994 255791, E-mail - qclabkasaragod@gmail.com



TC-16005

Test Report

Test Report No: KWA/QA/R/12/91/MB/12/069

ULR No.: TC-16085250000001415F

Report Date: 20-12-2025

Customer Name and Address SRI VIVEKANANDHA CENTRAL SCHOOL PERLA SRI VIVEKANANDHA CENTRAL SCHOOL PERLA P O PERLA KASARAGOD-671552 7012982749 HI FHC PERLA	1. Date of receipt	18-12-2025
	2. Sampling done by	The Customer(QUA_287166)
	3. Sample Code	66/25/44
	4. Source of sample	BORE WELL
	5. Sample condition	Good
	6. Name of sample	Drinking water
	7. Purpose of test	Non Domestic
	8. Sample quantity	250 ml
	9. Test performing dates	From: 18/12/2025 To: 20/12/2025

Sl No	Test Parameter	Test Method	Acceptable Limit as per IS 10500:2012	Result
1	Total Coliforms	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detectable in any 100 ml sample	Present
2	E.coli	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detectable in any 100 ml sample	Absent

Remarks:

1. The results reported relate only to the Sample received and tested.
2. This test report shall not be reproduced except in full without the written approval of the laboratory.


For **Analysed By**
Manjusha K
Technical Manager
Technical Manager
Quality Control District Lab Kasaragod
Kerala Water Authority
Vidyanagar, Kasaragod - 671123


Reviewed & Authorised By
KADEEJA PARVEEN SC
Quality Manager
Quality Manager
Quality Control District Lab
Kerala Water Authority
Vidyanagar, Kasaragod - 671123

* End of Report*

KWA/QC/DL/KSD/MB/R/43	Issue No: 02	Issue Date: 06.05.2022	Rev No: 04	Rev Date: 21.10.2025
-----------------------	--------------	------------------------	------------	-------------------------